

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE	OF PAGES
					1	1
2. AMENDMENT/MODIFICATION NO.		3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)
0002		09/9/2010				
6. ISSUED BY		7. ADMINISTARTED BY (If other than Item 6)				
DOT/FEDERAL AVIATION ADMINISTRATION SOUTHERN REGION, ASO-52 1701 COLUMBIA AVENUE COLLEGE PARK, GEORGIA 30337		SAME AS BLOCK 7				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)  TO ALL PROSPECTIVE BIDDERS				9A. AMENDMENT OF SOLICITATION NO. <b>DTFASO-10-R-00165</b>		
				9B. DATED (SEE ITEM 11) <b>08/25/10</b>		
				10A. MODIFICATION OF CONTRACT/ORDER NO.		
*TO BE COMPLETED BY VENDOR IF NOT COMPLETE				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>						
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer is ___ extended <b>X</b> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation on as amended, by one of the following methods: (a) By completing Item 8 and 15, and returning <b>1</b> copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.						
<input type="checkbox"/>						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14.						
<input type="checkbox"/>						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
<input type="checkbox"/>						
D. OTHER (Specify type of modification and authority)						
<input type="checkbox"/>						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <b>X</b> is required to sign this document and return <b>1</b> copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)						
Solicitation No. DTFASO-10-R-0065, to pressure wash brick, replace railings and replace ceiling tiles at Federal Aviation Administration, Jacksonville ARTCC, 37075 Aviation Lane, Hilliard, FL 32046. This amendment is to answer questions that were asked. See following page:						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
				Mattie L. Poteat Contract Specialist		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
				BY _____		09/9/10
(Signature of person authorized to sign)				(Signature of Contracting Officer)		

<b>REQUEST FOR INFORMATION (RFI)</b>	<b>RFI No.: 1</b>	<b>Date: 9-8-2010</b>
		<b>Hilliard, FL</b>
<b>Subject: Stairwell Railing Clarification</b>		
<b>Reason:</b> 1) Information: <input type="checkbox"/> 2) Clarification: <input checked="" type="checkbox"/> 3) Discrepancy: <input type="checkbox"/> 4) Other: <input type="checkbox"/>		
<b>Reference: Stairwell Railings</b>		
<p>1 <b>Description:</b> Note: This form shall be used to request technical information, clarification or direction as a result of field conditions or an inconsistency.</p> <p>Stairwell # 4 and # 1, the drawing states to replace "steel rails on Wall". Does the Guard Rail that Runs up the center of the stair stringer get replaced also?</p> <p>The vertical balusters measure 5" on center. Para. 2 under the scope of work states that "no railings with vertical balusters 4" on center are to be removed or replaced".</p> <p>The current condition in stairwell #4 and #1 exceed 4". Stairwell # 2 has the perforated metal panels. The existing first elevation of this stairwell does not have the perforated metal panels in it.</p> <p>Is the new (replacement) section on the first elevation supposed to have the perforated metal panels in it?</p>		
<b>Originator:</b>		<b>Date:</b>
<b>Reply:</b> Response to this RFI is a technical solution only to the above query and does not authorize additional cost.		
<b>Project Engineer: ?</b>		<b>Date:</b>
<b>Contracting Officer: Mattie Boteat</b>		<b>Date:</b>
<b>Distribution:</b>		

**ANSWERS:**

1. As indicated on the drawings, only the wall mounted handrails in stairwells #4 & #1 are to be replaced. Thus, the stair stringers up the center do not get replaced.
2. The new/replacement section on the first elevation of stairwell #2 should have the perforated metals panels installed on it.

**THERE ARE NO FURTHER CHANGES FOR THIS AMENDMENT 0002**